



# VIGNANA JYOTHI PUBLIC SCHOOL

Affiliation No. 130075, (New No. 3630021)  
G-16A, Madhura Nagar, Hyderabad - 500 038.  
Ph: 040-23752258, **Telefax:** 040-23750198

**E-mail:** vignanajyothi\_school@yahoo.co.in, **Website:** vjps.edu.in

To  
The Divisional Fire Officer  
Gowliguda  
HYDERABAD

Date: 30-04-2022

Dear Sir,

Sub: Request for Issue of Acknowledgement of Self Certification for Fire Safety Measures at cur Vignana Jyothi Public School Situated at Madhuranagar, Yousufguda, Hyderabad.

\* \* \*

Vignana Jyothi Public School ( Formerly Known as Spring Dales Public School established in the year 1998) is situated at D.No: 8-3-224/8/A/16 in Sy.No: 18 and 19 Madhuranagar, Yousufguda, Hyderabad with Ground + 3 upper floors with a height of 14.10mtrs. Built up area of each floor is 349.31sq.mtrs.

We have Installed the following fire fighting systems.

1. Fire down Comer System.
2. Manual Fire Alarm System.
3. Fire Extinguishers.

We are requesting you to issue us the acknowledgement of self certification for Fire Safety Measures. Kindly do the needful.

Thanking you

Yours Faithfully  
For VIGNAN JYOTHI PUBLIC SCHOOL

*J. Adunakundri*

Authorised Signatory

*Received*  
*11/05/2022*  
*11/05/2022*  
District Fire Officer  
Hyderabad



### Annexure-1

### Self Certification of Fire Safety Measures by School Management :

#### I. General Information for School Buildings of all Categories i.e A,B,C, & D

Sl.No.	Details	
1	Date of the opening of the school building	1998
2	Name of the Applicant	J. ARUNA KUMARI, PRINCIPAL, VIGNANA JYOTHI PUBLIC SCHOOL
3	Name and Address of the School	VIGNANA JYOTHI PUBLIC SCHOOL, D.NO:8-3-224/8/A/16, SY. NO: 19 & 19, MADHURA NAGAR, YOUSUFGUDA, HYDERABAD- 500038
4	Telephone Number and email of the applicant	PH NO :9100740105, Email : vjps_aruna2011@yahoo.com
5	Height of the building (in meters)	14.10 MTS
6	No. of Floors	ground + 3Floors
7	Abutting Road width (in meters)	15.00 MTS
8	Built-up area of each floor in Sq.Mtrs	
	Ground	349.31 SQM
	Floor 1	349.31 SQM
	Floor 2	349.31 SQM
	Floor 3	349.31 SQM
9	Number of Staircases	1
	Staircase 1 (width in meters)	1.2 MTS
	Staircase 2 (width in meters)	
10	Width of each staircase	
11	Open Spaces	
	Front (width in meters)	6.3 MTS
	Side 1 (width in meters)	4.7 MTS
	Side 2 (width in meters)	7.3 MTS
	Rear (width in Meters)	NIL

*J. Aruna Kumari*  
Signature with date of 30.4.22  
School Authority & Seal

SENIOR PRINCIPAL  
VIGNANA JYOTHI PUBLIC SCHOOL  
16 A, Madhura Nagar, Hyderabad-38



**B) School Buildings with Ground plus three floors and less than 15 meters in height**

Sl.No.	Fire Equipment required	Scale of fire equipment as per Norms	Required	Provided Yes/No
1	Fire Extinguishers (IS 2190:2010)	Two 09 liters water expelling extinguishers or ABC 4 Kgs fire extinguisher, for every 200 square meters with minimum of 04 extinguishers per compartment/floor. The extinguisher should be so located as to be available within 15 meter radius.		Yes
2	First Aid Hose Reel (IS 884:1985)	1 No for every 1000 square meter		Yes
3	Terrace tank over respective tower terrace	10000 Liters (5000 literes additionally shall be provided if basement exceeds 200 square meters)		Yes
4	Automatic Sprinkler System (IS 15105:2002). The IS standard may be downloaded from <a href="http://www.bis.gov.in">www.https://bis.gov.in</a>	To be installed in basement. If area of basement exceeds 200 square meters.		NA
5	Pump Capacity in LPM at the terrace tank level with minimum pressure of 3.5Kg/cm <sup>2</sup>	450 LPM (450 LPM additionally shall be provided if basement exceeds 200 square meters)		Yes
<b>ADDITIONAL FIRE SAFETY MEASURES IN LIEU OF DEFICINENY IN SETBACKS.</b>				
1	Water Shower Curtain	Water shower curtain shall be provided in all floors ono the side/sides having deficiency of setback to overcome exposure hazard from fires from neighboring property.		Yes
2	Fire Brigade inlet	02 Nos		Yes

Note: If the floor area in a single floor more than 500 square meters and if there is only single stair case, a second stair case of 1.5 meters width shall be provided with concrete/metal structure.

*J. Adunak*  
 Signature with date of School  
 Authority and Seal

**SENIOR PRINCIPAL**  
**VIGNANA JYOTHI PUBLIC SCHOOL**  
 G-16 A, Madhura Nagar, Hyderabad-38



ii) General Fire Safety Measures which should be followed by all schools:-

Sl.No	General Fire Safety Measures	Whether followed Yes/No
1	The school building shall not be housed in temporary structure with roofs of tent cloth, or any other combustible materials.	YES
2	It should be ensured tht the available Fire Safety Equipment is always in good working condition.	YES
3	Pre-school, Kinder Garden and Class/Grade 1 students shall be located on Ground Floor/level of Exit discharge and Class/Greade 2 students shall be located not above one floor higher than Ground Floor/level of Exit discharge.	YES
4	Kitchen should be constructed/provided away from the school building.	NA
5	All Schools shall prepare an Evacuation plan in consultation with local fire officer.	YES
6	All Teachers/Employees should be trained in operating the avaialbe Fire Safety Equipment in the building.	YES
7	All Exits/Escape routes shall be kept freefrom any obstructions for free passage in case of any emergency.	YES
8	All the internal staircases, lifts, lobbies and corridors should be adqutely ventilated and illuminated.	YES
9	If the School is provided with central Air-conditioning system, all safety measures as per Clause 10.1 of IS 14435:1997 should be followed.	NA
10	School Buildings shall be kept free from inflammable and toxic material. If storage is inevitable, they should be stored safely.	YES
11	Any Hazardous/Combustible Material/Volatile Flammable liquids shall not be stored in School buildings	YES
12	Dos and DONTs in case of any Fire/Emergency shall be properly displayed at Strategic locations of the building.	YES
13	Auto Glow sign boards shall be provided indicating Exits/Escape Routes	YES
14	Electric Wiringn in the entire building shall be cheked and certified by the Competent authority	YES
15	Structural and stability of the building shall be checked and certified by the competent authority	YES
16	Public Address System shall be provided for use in case of any emergency and this system shall cover the entire building	YES
17	Detailed information regarding the number of students in each class room and the number of teacher/employees working shall be dispalyed at Strategic locations of the building.	YES
18	Display all emergency supporting numbers such as nearest fire stations, police stations, hospitals/ambulance etc on all floors and at strategic locations.	YES
19	A pictorial map with the details of Entries/Exists, details of Clas Rooms/Laboratories/Staff Rooms and open place (Assembly Point) of the School Building shall be prepared and displayed in Strategic Locations.	YES
20	If basement area of the building exceeds 200 square meters, required to provide Automatic Sprinkler system as per IS 15105:2002	NA

We VIGNANA JYOTHI PUBLIC SCHOOL Management/Correspondent hereby certify that the information furnished is correct and if it is noticed at any time that the information provided is false, we understand that our school Affiliation may be cancelled by the Concerned Authority. We have installed fire safety measures as per the Annexire-I and undertake to maintain the same in good working condition at all times.

*J. Anurak Reddy*  
 Signature with date of School Authority and seal. 30.4.22  
 Name and Designation

**SENIOR PRINCIPAL**  
**VIGNANA JYOTHI PUBLIC SCHOOL**  
 G-16 A, Madhura Nagar, Hyderabad-38